

ELECTRICAL INSTALLATION CONDITION REPORT Requirements For Electrical Installations Report

COMMERCIAL INDUSTRIAL		Certificate Number:	100026	
1 DETAI	LS OF THE PERSON ORDERING THE REPO	DT		
Client:	Whitehall Mansion Management Company LTD	KI		
	Whitehall Mansion, Shrewsbury, Shropshire, SY2 5	A D		
Address:	Writteriali Marisiori, Sillewsbury, Sillopsille, 312 57	AP		
2 REAS	ON FOR PRODUCING THIS REPORT			
Reason for	producing this report:			
Landlords s	afety report.			
Date on whic	h inspection and testing was carried out: 03/	05/2024		
3 DETAI	LS OF THE INSTALLATION WHICH IS THE	SUBJECT OF THIS	REPORT	
Installation	Address: Same as Client Address			
Description o	f premises: Domestic N/A Commercial	Industrial N/A Other	·: N/A	
Estimated ag	e of wiring system: 15 years Evidence alteration	of additions/ No if	yes, estimated age:	N/A years
Installation re	ecords available? (Regulation 651.1)	Date of last	inspection:	N/A
	NT AND LIMITATIONS OF INSPECTION AN			
	ne electrical installation covered by this report:	DIESTING		
	DB's 1&2 ONLY			
100% of ins	stallation tested, 25% of accessories removed for ins	pection.		
Agreed limita	itions including the reasons (see Regulation 653.2):			
_	or inspection of any items out of view or reach. No L	ifting of floor boards or	inspection of loft s	расе.
Agreed with:	N/A			
	imitations including the reasons:			
N/A				

The inspection and testing detailed in this report and accompanying schedules have been carried out in accordance with BS 7671:2018 (IET Wiring Regulations) as amended to 2022.

It should be noted that cables concealed within trunking and conduits, under floors, in roof spaces, and generally within the fabric of the building or underground, have not been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.

SUMMARY OF THE CONDITION OF THE INSTALLATION

See section 8 for a summary of the general condition of the installation in terms of electrical safety.

Overall assessment of the installation in terms of it's suitability for continued use*:

SATISFACTORY

* An unsatisfactory assessment indicates that dangerous (Code C1) and/or potentially dangerous (Code C2) conditions have been identified.

RECOMMENDATIONS

 $\sqrt{}$ here the overall assessment of the suitability of the installation for continued use on page 1 is stated as 'UNSATISFACTORY', I/We recommend that any observations classified as 'Code 1 - Danger Present' or 'Code 2 - Potentially dangerous' are acted upon as a matter of urgency.

Investigation without delay is recommended for observations identified as 'FI - Further Investigation Required'.

Observations classified as 'Code 3 - Improvement recommended' should be given due consideration.

Subject to the necessary remedial action being taken, I/we recommend that the installation is further inspected and tested by:

5 Years

Note: The proposed date for the next inspection should take into consideration the frequency and quality of maintenance that the installation can reasonably be expected to receive during its intended life. The period should be agreed between relevant parties.

OBSERVATIONS AND RECOMMENDATIONS FOR ACTIONS TO BE TAKEN Referring to the attached schedules of inspection and test results, and subject to the limitations specified on page 1 of this report under 'Extent of the Installation and Limitations of Inspection and Testing': N/A There are no items adversely affecting electrical safety or The following observations and recommendations are made Observations Classification Code

Item No		Observations	Classification Code
1	several outside lights are not functioning	but this does not impair electrical safety	N/A
2	window fan damaged in mains room but	has been disconnected / fuse removed form spur	N/A
3	water heater in mains room not function	ing / has been disconnected / fuse removed from spur	N/A
0	- Callandon and an an announdate has been all		H (-)
	e following codes, as appropriate, has been all le for the installation the degree of urgency fo	ocated to each of the observations made above to indicate to remedial action.	tne person(s)
Risk	ger Present of injury. Immediate dial action required C2 Potentially da required	angerous C3 Improvement FI Further invariant recommended required w	estigation ithout delay
Immedia	te remedial action required for items:	N/A	
Urgent r	emedial action required for items:	N/A	
Improve	ment recommended for items:	N/A	
Further i	nvestigation required for items:	N/A	

GENERAL CONDITION OF THE INSTALLATION General condition of the installation (in terms of electrical safety): installation appears to be in a satisfactory condition													
9 DECLAR	ATION												
I/We, being th signatures below inspection and to	e person(s) r v), particulars esting, hereb urate assessn	s of which are de y declare that th	escribed abo le information	ve, hav	ing exercise s report, inc	d reason cluding th	able skill a ne observa	ind car tions a	indicated by my/o e when carrying o nd the attached s stated extent and	out the chedules,			
Trading Title:	Salop Elect	rical LTD											
Address:	38 Redwin Shrewsbur	O .					ration Num licable):	nber	N/A				
	Shropshire	•					one Numb	er:	01743 60402	0			
			Postcode	SY2	25SZ	·							
For the INSPEC	CTION, TEST	ING AND ASSE			eport:								
Name:	A. MORGAN	Position	n: DI	IRECTO	R Si	gnature:	A	N	Date: 0	3/05/2024			
10 SUPPLY Earthing	ı	TERISTICS A			G ARRAN	GEME	NTS	ı					
Arrangements		er and Type of Li 1-phase	2-phase		Nature Nominal v		y Paramete	 	Supply Protect				
	AC:	(2-wire): N/A 3-phase	(3-wire): 3-phase		U/Uo:	J	40	į	BS (EN):	LIM			
TN-C-S:	I N/A	(3-wire): V	(4-wire):		Nominal fr			- 1	Type:	LIM			
1177	DC: N/A	2-wire: N/A	3-wire:	N/A	current, lp	f:	LIN.	į	Rated current:	LIM A			
TT: N/A	Other:				l loop impe	dance, Ze	e: LII\	/Ι Ω _Ι					
1171	1	n of supply polai			Number of								
Means of Earth		INSTALLAT			D TO TN ation Earth I			plicab	e)				
Distributor's facility:	✓	Туре:	N/A		Location:				N/A				
Installation					Method o	of .			N/A				
earth electrode:	N/A	Resistance to I	Earth:	V/A Ω	measure				IN/ A				
	 vitch-Fuse / (Circuit-Breaker /	RCD	Ν/Α Ω		ment:			IN/A				
earth electrode:	 vitch-Fuse / (RCD	ν/Α Ω		ment:	 -3 Isolato	 r	Number of poles:	2			
earth electrode: Main Switch / Sw Location: Current rating:	vitch-Fuse / C	Circuit-Breaker /	RCD d		measure	ment: 60947	-3 Isolato e rating:			2			
earth electrode: Main Switch / Sv Location:	vitch-Fuse / C	Circuit-Breaker / mains cupboard Fuse/device ra Rated residual	RCD d ting or setti		BS (EN): 100 A	60947 Voltag		24	Number of poles: (0 V Measured	2 N/A ms			
earth electrode: Main Switch / Sw Location: Current rating: If RCD main swit RCD Type:	vitch-Fuse / C I 100 A ch: N/A	Circuit-Breaker / mains cupboard Fuse/device ra Rated residual current (IΔn):	RCD d ting or setti	ng:	measure BS (EN): 100 A mA Rat del	60947 Voltag ed time	e rating:	24 ms	Number of poles: O V Measured operating time:				
earth electrode: Main Switch / Sw Location: Current rating: If RCD main swit RCD Type: Earthing and Pro Earthing conduct	vitch-Fuse / 0 1 100 A ch: N/A tective Bondi	Circuit-Breaker / mains cupboard Fuse/device ra Rated residual current (IΔn):	RCD d ting or setti operating Connect	ng: N/A	measure BS (EN): 100 A mA Rat del Bonc To w	60947 Voltaged time ay: ling of exater insta	e rating: N/A rating:	24 ms	Number of poles: O V Measured operating time: tive parts To gas installat	N/A ms			
earth electrode: Main Switch / Sw Location: Current rating: If RCD main swit RCD Type: Earthing and Pro	vitch-Fuse / C 1 100 A ch: N/A tective Bondi or Copper	Fuse/device ra Rated residual current (I _{Δn}): ng Conductors csa: 16 mr	RCD d ting or setti operating Connect	ng: N/A	measure BS (EN): 100 A mA Rat del Bonc To w pipes	60947 Voltaged time ay: ling of exater installa	N/A n	24 ms	Number of poles: O V Measured operating time:	N/A ms			

Ref: 1000265 - Page: 3 of 10

12/IN	ISPECTION SCHEDULE	
Item	Description	Outcome
1.0	EXTERNAL CONDITION OF INTAKE EQUIPMENT (VISUAL INSPECTION ONLY) Where inadequacies in intake equipment are encountered, it is recommended that the person ordering the rep the appropriate authority	ort informs
1.1	Service cable	Pass
1.2	Service head	Pass
1.3	Earthing arrangements	Pass
1.4	Meter tails	Pass
1.5	Metering equipment	Pass
1.6	Isolator (where present)	Pass
2.0	PRESENCE OF ADEQUATE ARRANGEMENTS FOR PARALLEL OR SWITCHED ALTERNATIVE SOURCES	
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	N/A
2.2	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	N/A
3.0	AUTOMATIC DISCONNECTION OF SUPPLY	
3.1	Main earthing/bonding arrangements (411.3; Chap 54):	
3.1.1	Presence of distributor's earthing arrangement (542.1.2.1; 542.1.2.2), or presence of installation earth electrode arrangement (542.1.2.3)	Pass
3.1.2	Adequacy of earthing conductor size (542.3; 543.1.1)	Pass
3.1.3	Adequacy of earthing conductor connections (542.3.2)	Pass
3.1.4	Accessibility of earthing conductor connections (543.3.2)	Pass
3.1.5	Adequacy of main protective bonding conductor sizes (544.1)	Pass
3.1.6	Adequacy and location of main protective bonding conductor connections (543.3.2; 544.1.2)	Pass
3.1.7	Accessibility of all protective bonding connections (543.3.2)	N/A
3.1.8	Provision of earthing/bonding labels at all appropriate locations (514.13)	Pass
3.2	FELV - requirements satisfied (411.7; 411.7.1)	N/A
4.0	OTHER METHODS OF PROTECTION (where any of the methods listed below are employed details sh provided on separate sheets)	ould be
4.1	Non-conducting location (418.1)	N/A
4.2	Earth-free local equipotential bonding (418.2)	N/A
4.3	Electrical separation (Section 413; 418.3)	N/A
4.4	Double insulation (Section 412)	N/A
4.5	Reinforced insulation (Section 412)	N/A
5.0	DISTRIBUTION EQUIPMENT	
5.1	Adequacy of working space/accessibility to equipment (132.12; 513.1)	Pass
5.2	Security of fixing (134.1.1)	Pass
5.3	Condition of insulation of live parts (416.1)	Pass
5.4	Adequacy/security of barriers (416.2)	Pass
5.5	Condition of enclosure(s) in terms of IP rating etc (416.2)	Pass
5.6	Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5)	Pass
5.7	Enclosure not damaged/deteriorated so as to impair safety (651.2)	Pass
5.8	Presence and effectiveness of obstacles (417.2)	N/A
5.9	Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2)	Pass
5.10	Operation of main switch(es) (functional check) (643.10)	Pass
5.11	Manual operation of circuit-breakers, RCDs and AFDDs to prove functionality (643.10)	Pass
5.12	Confirmation that integral test button/switch causes RCD(s) to trip when operated (functional check) (643.10)	Pass
5.13	RCD(s) provided for fault protection – includes RCBOs (411.4.204; 411.5.2; 531.2)	N/A
5.14	RCD(s) provided for additional protection/requirements, where required – includes RCBOs (411.3.3; 415.1)	Pass
OUTCON Accepta condition	ble DASS Unacceptable C1 as C2 Improvement C2 Further FI Not Not Not Improvement C3 Further FI Not N	Not N/A

12 IN	ISPECTION SCHEDULE (CONTINUED)	
Item	Description	Outcome
5.15	Presence of RCD six-monthly test notice, where required (514.12.2)	Pass
5.16	Presence of diagrams, charts or schedules at or near equipment, where required (514.9.1)	Pass
5.17	Presence of alternative supply warning notice at or near equipment, where required (514.15)	N/A
5.18	Presence of next inspection recommendation label (514.12.1)	Pass
5.19	Presence of other required labelling (please specify) (Section 514)	N/A
5.20	Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.5; 411.6; Sections 432, 433)	Pass
5.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	Pass
5.22	Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.5; 522.8.11)	Pass
5.23	Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1)	Pass
6.0	DISTRIBUTION CIRCUITS	
6.1	Identification of conductors (514.3.1)	Pass
6.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	LIM
6.3	Condition of insulation of live parts (416.1)	Pass
6.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)	N/A
6.5	Suitability of containment systems for continued use (including flexible conduit) (Section 522)	N/A
6.6	Cables correctly terminated in enclosures (Section 526)	Pass
6.7	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)	Pass
6.8	Examination of cables for signs of unacceptable thermal or mechanical damage/deterioration (421.1; 522.6)	Pass
6.9	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	Pass
6.10	Adequacy of protective devices: type and rated current for fault protection (411.3)	Pass
6.11	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	Pass
6.12	Coordination between conductors and overload protective devices (433.1; 533.2.1)	Pass
6.13	Cable installation methods/practices with regard to the type and nature of installation and external influences (Section 522)	Pass
6.14	Where exposed to direct sunlight, cable of a suitable type (522.11.1)	LIM
6.15	Cables concealed under floors, above ceilings, in walls/partitions less than 50mm from a surface, ar partitions containing metal parts:	nd in
6.15.1	Installed in prescribed zones (see Section 4. Extent and limitations) (522.6.202) or	LIM
6.15.2	Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section 4. Extent and limitations) (522.6.204)	LIM
6.16	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	Pass
6.17	Band II cables segregated/separated from Band I cables (528.1)	LIM
6.18	Cables segregated/separated from non-electrical services (528.3)	LIM
6.19	Condition of circuit accessories (651.2)	Pass
6.20	Suitability of circuit accessories for external influences (512.2)	Pass
6.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	Pass
6.22	Adequacy of connections, including cpcs, within accessories and to fixed and stationary equipment – identify/record numbers and locations of items inspected (Section 526)	Pass
6.23	Presence, operation and correct location of appropriate devices for isolation and switching (Chapter 46; Section 537)	Pass
6.24	General condition of wiring systems (651.2)	Pass
6.25	Temperature rating of cable insulation (522.1.1; Table 52.1)	Pass
7.0	FINAL CIRCUITS	
7.1	Identification of conductors (514.3.1)	Pass
7.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	LIM
7.3	Condition of insulation of live parts (416.1)	Pass
OUTCOM Acceptal condition	ole DASS Unacceptable C1 as C2 Improvement C2 Further FI Not Not Not Improvement Not Not	ot icable N/A

12 IN	ISPECTION SCHEDULE (CONTINUED)	
Item	Description	Outcome
7.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)	N/A
7.5	Suitability of containment systems for continued use (including flexible conduit) (Section 522)	N/A
7.6	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	Pass
7.7	Adequacy of protective devices: type and rated current for fault protection (411.3)	Pass
7.8	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	Pass
7.9	Co-ordination between conductors and overload protective devices (433.1; 533.2.1)	Pass
7.10	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)	Pass
7.11	Cables concealed under floors, above ceilings, in walls/partitions, adequately protected against dar (522.6.201; 522.6.202; 522.6.203; 522.6.204):	nage
7.11.1	Installed in prescribed zones (see Section 4. Extent and limitations) (522.6.202)	LIM
7.11.2	Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section 4. Extent and limitations) (522.6.201; 522.6.204)	LIM
7.12	Provision of additional protection by 30mA RCD:	
7.12.1	For all socket-outlets of rating 32A or less, unless an exemption is permitted (411.3.3) *	Pass
7.12.2	For the supply of mobile equipment not exceeding 32A rating for use outdoors (411.3.3) *	Pass
7.12.3	For cables concealed in walls at a depth of less than 50mm (522.6.202, 522.6.203) *	Pass
7.12.4	For cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203) *	Pass
7.12.5	For final circuits supplying luminaires within domestic (household) premises (411.3.4) *	Pass
	* Note: Older installations designed prior to BS 7671:2018 may not have been provided with RCDs for addition protection.	ial
7.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	Pass
7.14	Band II cables segregated/separated from Band I cables (528.1)	LIM
7.15	Cables segregated/separated from non-electrical services (528.3)	LIM
7.16	Termination of cables at enclosures – identify/record numbers and locations of items inspected (Se	ction
7.16.1	526): Connections under no undue strain (526.6)	Pass
		Pass Pass
		Pass
	Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)	
7.17	Condition of accessories including socket-outlets, switches and joint boxes (651.2)	Pass
7.18	Suitability of accessories for external influences (512.2)	Pass
7.19	Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3)	Pass
8.0	ISOLATION AND SWITCHING	
8.1	Isolators (Sections 460; 537):	NI/A
8.1.1	Presence and condition of appropriate devices (Section 462; 537.2.7)	N/A
8.1.2	Acceptable location – state if local or remote from equipment in question (Section 462; 537.2.7)	N/A
8.1.3	Capable of being secured in the OFF position (462.3)	N/A
8.1.4	Correct operation verified (643.10)	N/A
8.1.5	Clearly identified by position and/or durable marking (537.2.6)	N/A
8.1.6	Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2) Switching off for mechanical maintenance (Section 464; 537.3.2):	N/A
8.2.1	Presence and condition of appropriate devices (464.1; 537.3.2)	N/A
8.2.2	Acceptable location – state if local or remote from equipment in question (537.3.2.4)	N/A
8.2.3	Capable of being secured in the OFF position (462.3)	N/A
8.2.4	Correct operation verified (643.10)	N/A
8.2.5	Clearly identified by position and/or durable marking (537.3.2.4)	N/A
0.2.3	oleany identified by position and/or adiable marking (557.5.2.4)	IV/A
OUTCOM Acceptal condition	ble DASS Unacceptable C1 or C2 Improvement C2 Further FI Not NAV Limitation LIM	Not N/A

12/IN	ISPECTION SCHEDULE (CONTINUED)	
Item	Description	Outcome
8.3	Emergency switching/stopping (Section 465; 537.3.3):	
8.3.1	Presence and condition of appropriate devices (Section 465; 537.3.3; 537.4)	N/A
8.3.2	Readily accessible for operation where danger might occur (537.3.3.6)	N/A
8.3.3	Correct operation verified (643.10)	N/A
8.3.4	Clearly identified by position and/or durable marking (537.3.3.6)	N/A
8.4	Functional switching (Section 463; 537.3.1):	
8.4.1	Presence and condition of appropriate devices (537.3.1.1; 537.3.1.2)	Pass
8.4.2	Correct operation verified (537.3.1.1; 537.3.1.2)	Pass
9.0	CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)	
9.1	Condition of equipment in terms of IP rating etc (416.2)	Pass
9.2	Equipment does not constitute a fire hazard (Section 421)	Pass
9.3	Enclosure not damaged/deteriorated so as to impair safety (134.1.1; 416.2; 512.2)	Pass
9.4	Suitability for the environment and external influences (512.2)	Pass
9.5	Security of fixing (134.1.1)	Pass
9.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire: List number and location of luminaires inspected (separate page) (527.2)	Pass
9.7	Recessed luminaires (downlighters):	
9.7.1	Correct type of lamps fitted (559.3.1)	N/A
9.7.2	Installed to minimise build-up of heat by use of 'fire rated' fittings, insulation displacement box or similar (421.1.2)	N/A
9.7.3	No signs of overheating to surrounding building fabric (559.4.1)	N/A
9.7.4	No signs of overheating to conductors/terminations (526.1)	N/A
10.0	LOCATION(S) CONTAINING A BATH OR SHOWER	<u>'</u>
10.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30mA (701.411.3.3)	N/A
10.2	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)	N/A
10.3	Shaver supply units comply with BS EN 61558-2-5 formerly BS 3535 (701.512.3)	N/A
10.4	Presence of supplementary bonding conductors, unless not required by BS 7671:2018 (701.415.2)	N/A
10.5	Low voltage (e.g. 230 V) socket-outlets sited at least 2.5m from zone 1 (701.512.3)	N/A
10.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)	N/A
10.7	Suitability of accessories and controlgear etc. for a particular zone (701.512.3)	N/A
10.8	Suitability of current-using equipment for particular position within the location (701.55)	N/A
11.0	OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS	
	List all other special installation or locations present, if any. (Record separately the results of particular inspect	T .
11.1	N/A	N/A
11.2	N/A	N/A
11.3	N/A	N/A
11.4	N/A	N/A
11.5	N/A	N/A
12.0	PROSUMER'S LOW VOLTAGE ELECTRICAL INSTALLATION(S) Where the installation includes additional requirements and recommendations relating to Chapter 82, additional items should be added to the checklist below.	I inspection
12.1	N/A	N/A
12.2	N/A	N/A
12.3	N/A	N/A
12.4	N/A	N/A
12.5	N/A	N/A
Inspection Name:		3/05/2024
OUTCON Accepta	// Ingresentable Improvement Further Net	Not
condition	ble PASS Unacceptable C1 or C2 Improvement C3 Further FI Not N/V Limitation LIM app	licable N/A

	DISTRIBUTION	BOARD D	ETA	LS																										
DB r	reference:		DB 1					Lo	cation:			ma	ins cu	upboard				Supp	olied f	rom	:				Ori	gin				
Distrib	oution circuit OCPD:	BS (EN):				13	361				-	Гуре:		2	Rati	ng/S	ettir	ng:	80	Α		No	of p	hases		1				
SPD D	etails: Types:	T1 N/A	T2	N/A	Т	3	N/A	Ν	I/A 🗸					ndicator					N/A	١										
Confir	mation of supply pola								e sequenc	0		V/A	ICTION	ality indi	Cator	pres	sent,	,			Zs a	+ DR·	().11 <u>c</u>)		pf at	DR:	2 1	4 kA
	11 3 1	3							<u> </u>			W/ /\												J. 1 1 <u>\$</u>		- '	рі ат	<u></u>	2.1	7 KA
	SCHEDULE OF C	TRCUIT	EIAI	LS.			S I I		ULIS							7507.01									DETAIL	<u> </u>				
				Cond	ductor o		DETAI	(S)	Overcurr	ent n	rotecti	ive dev	vice		RCD				Cont	inuity	· (O)			ation res		.5	Zs	RC	,D	AFDD
						Nun	nber		373.341.	J								Ring	final ci			†R2	modic				23			
Circuit number	Circuit descr	ription	Type of wiring	Reference method	Number of points served	Live (mm ²)	cpc (mm ²)	Max disconnect time permitted by BS7671	BS (EN)	Туре	Rating (A)	Breaking capacity (kA)	Maximum permitted Zs (Ω)	BS (EN)	Туре	Rated operating current (mA)	Rating (A)	rı (line)	r _n (neutral)	r2 (cpc)	R1+R2	R2	Test voltage (V)	Live - Live (MΩ)	Live - Earth (ΜΩ)	Polarity (tick)	Maximum measured (Ω)	Disconnection time (ms)	Test button operation (tick)	Manual test button operation (tick)
1	spare		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		-	-		
2	spare		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		-	-		
3	outside lights		А	С	14	2.5	1.5	0.4	60898	В	16	10	2.73	61008	А	30	100	N/A	N/A	N/A	0.50	N/A	500	> 200	> 200	~	0.66	189	~	N/A
4	spare		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		-	-		
5	spare		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		-	-		
6	internal lights		А	С	10	1.0	1.0	0.4	60898	В	6	10	7.28	61008	А	30	100	N/A	N/A	N/A	3.35	N/A	500	> 200	> 200	~	3.49	163	~	N/A
7	fire alarm panel		А	С	1	1.5	1.0	0.4	60898	В	6	10	7.28	61008	А	30	100	N/A	N/A	N/A	0.21	N/A	500	> 200	> 200	~	0.32	163	~	N/A
8	water heater & extra	ctor fan	А	С	2	2.5	1.5	0.4	60898	В	16	10	2.73	61008	А	30	100	N/A	N/A	N/A	0.18	N/A	500	> 200	> 200	~	0.29	163	~	N/A
9	gates & intercom syst	tem	А	С	1	2.5	1.5	0.4	60898	В	16	10	2.73	61008	А	30	100	N/A	N/A	N/A	LIM	N/A	500	LIM	LIM	~	LIM	163	~	N/A
10	stairwell sockets		А	С	2	2.5	1.5	0.4	60898	В	16	10	2.73	61008	А	30	100	N/A	N/A	N/A	0.60	N/A	500	> 200	> 200	~	0.71	163	~	N/A
TYP	AS FOR Thermoplast FE OF insulated/shea RI NG cables	thed cal	B noplastic bles in ic condui		(C ermople cables etallic		t	D Thermopla cables i metallic tru	in		(E ermopla cables in etallic tr	n	Thern /SW/	F noplas			G ermoset WA cab		in	H Mine sulated	eral	es		(0 - Oth			
	DETAILS OF TES																													
	Details of test instruments used (serial and/or asset numbers) ulti-functional: MEGGER 1720								nsulation	roole	tono					N	l/A				Cox	ntinui	1+. /.				N/A			
	electrode resistance:								arth fault				nco.								RC		ıty.							
				N/A					.artir rault	1001	, 1111¢	Jouan				IN	I/A				100	J.					N/A			
Nam	ne: A. M	//ORGAN		F	Positio	on:			DIRE	Sign	ature				A	re	2				Date	e:	03	/05/	2024	1				

SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS																																
DB re	eference	:	D	В1			Location: mains cupboard											Supp	olied	from					Orio	gin						
						CIR	CUIT	DETAI	ILS														Т	EST R	ESULT	DETAILS	S					
					Conc	ductor o			(s)	Overcurr	ent p	otecti	ve dev	vice		RCI	D			Con	tinuity	(Ω)		Insula	ation res	istance		Zs	RC	D	AFDE	
					po		Nur and	nber size	time 37671										Ring	final c	ircuit	R1- or	₩2 ₩2			<u>a</u>					ton	
Circuit number		Circuit description		Type of wiring	Reference method	Number of points served	Live (mm ²)	cpc (mm ²)	Max disconnect time permitted by BS7671	BS (EN)	Type	Rating (A)	Breaking capacity (kA)	Maximum permitted Zs (Ω)	BS (EN)	Type Rated operating current (mA) Rating (A)		Rating (A)	r1 (line)	r _n (neutral)	r2 (cpc)	R1+R2	R2	Test voltage (V)	Live - Live (MΩ)	Live - Earth (MΩ)	Polarity (tick)	Maximum measured (Ω)	Disconnection time (ms)	Test button operation (tick)	Manual test button operation (tick)	
CODE: TYPI WIR	S FOR E OF RING	A Thermoplastic insulated/sheathed cables	Thermop cables metallic	olastic s in			C ermopl cables etallic	in	it	Thermopla cables i metallic tru	n		C	E ermopla cables in etallic tr	า		F ermoplas WA cable						Mine	H Mineral lated cables				O - Other				

	DISTRIBUTION	BOARD [DETA	ILS																										
DB r	reference: D	B 2 (off pea	ak stor	age h	eater	rs)		Lo	cation:			ma	ins cı	upboard				Supp	olied f	rom:					Ori	gin				
Distrib	oution circuit OCPD:	BS (EN):				13	361				-	Гуре		2	Rati	ng/S	ettir	ng:	80	Α		No	of p	hases	:	1				
SPD D	etails: Types:	T1 N/A	T2	N/A	٠ -	Г3	N/A	N	/A /					ndicator on ality indicator					N/A	١										
	mation of supply polar								e sequenc	0		V/A	ICTION	ianty mun	Jatui	pres	em,)			Zs at	· DR·		LIM s			of at	DR:	111	√l kA
	****											W/ /\									2 5 at	. 06.	'	LIIVI 2			ρι αι 	<u></u>	LIIV	/
	SCHEDULE OF CI	RCUITL	JETA	ILS		CUIT			ULIS														ECT D	ECHT	DETAIL:	c				
/				Con	ductor		DETAI	(%)	Overcurr	ent p	rotecti	ve dev	/ice		RCD				Cont	inuity	(Ω)			ation res		3	Zs	RC		AFDD
				7		Number and size												Ring	final ci		R1+	-R2								
per	Circuit descrip	otion	ing	Reference method	p		JIZC	Max disconnect time permitted by BS7671				a	(v) sz			ating ()							3	(MR)	Earth (MΩ)	⊋	(a	no	tick)	Manual test button operation (tick)
mn 1			of wiring	nce r	er of served	nm ²)	(mm ²)	isconi tted b	2		€	ing ity (kA)	um tted Z	9		opera	€	(e)	utral)	(C)	2		oltag	- Live (Ma)	Earth	y (tic	num rred (ms)	utton tion (al test tion (
Circuit number			Type	Refere	Number of points serve	Live (mm ²)	cpc (n	Max d permi	BS (EN)	Туре	Rating (A)	Breaking capacity (Maximum	BS (EN)	Туре	Rated operating current (mA)	Rating (A)	r1 (line)	r _n (neutral)	r2 (cpc)	R1+R2	R2	Test voltage (V)	Live -	Live -	Polarity (tick)	Maximum measured (Ω)	Disconnection time (ms)	Test button operation (tick)	Manua
1	top floor storage heate	er	Α	С	1	2.5	1.5		60898	В	16	10	2.73	61008	AC	30	63					N/A	500			~	LIM	LIM	~	N/A
2	second floor storage h	eater	А	С	1	2.5	1.5	0.4	60898	В	16	10	2.73	61008	AC	30	63	N/A	N/A	N/A	0.48	N/A	500	> 200	> 200	~	LIM	LIM	~	N/A
3	first floor storage heat	er	А	С	1	2.5	1.5	0.4	60898	В	16	10	2.73	61008	AC	30	63	N/A	N/A	N/A	0.37	N/A	500	> 200	> 200	~	LIM	LIM	~	N/A
4	ground floor storage h	eater	А	С	1	2.5	1.5	0.4	60898	В	16	10	2.73	61008	AC	30	63	N/A	N/A	N/A	0.07	N/A	500	> 200	> 200	~	LIM	LIM	~	N/A
5	spare		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		-	-		
6	spare		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		-	-		
	A Thermoplastic insulated/sheath		B moplastion			C ermop			D Thermopla				E ermopla		Thern	F noplas	tic	The	G ermoset	tina		H Mine				(O - Oth			
TYP		cables etallic		it	cables i metallic tru				cables in etallic tr			cable			WA cab		ins		d cable	es			N/A	\ 						
	DETAILS OF TEST INSTRUMENTS																													
Details of test instruments used (serial and/or asset nu Multi-functional: MEGGER 1720								L	nsulation	racio	stanc	۵.				N	/A				Cor	ntinui	itv.				N/A			
	electrode resistance:		IVILO	N/A		,			arth fault				nce.										ıty.				N/A			
				IN/A					a. tri idali	.00		Jaar	.50.			IN	/A				RCD:						IN/A			
Nam	TESTED BY	ORGAN			Positi	on:		DIDECTOR						Signa	aturo				Date: 03/05/2024							1				
ivaii	A. IVI			าบราเป	OH.		DIRECTOR							iture				11	L					Date	5.	03	/03/	ZUZ ²	t	

ELECTRICAL INSTALLATION CONDITION REPORT GUIDANCE FOR RECIPIENTS

(to be appended to the Report)

This Report is an important and valuable document which should be retained for future reference.

- 1. The purpose of this Report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section 5). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section 7).
- 2. This Report is only valid if accompanied by the Inspection Schedule(s) and the Schedule(s) of Circuit Details and Test Results
- 3. The person ordering the Report should have received the 'original' Report and the inspector should have retained a duplicate.
- 4. The original Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner/occupier with details of the condition of the electrical installation at the time the Report was issued.
- 5. Section 4 (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.
- 6. Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section 4.
- 7. For items classified in Section 7 as CI (Danger present), the safety of those using the installation is at risk, and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work immediately.
- 8. For items classified in Section 7 as C2 (Potentially dangerous), the safety of those using the installation at risk and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.
- 9. Where it has been stated in Section 7 that an observation requires further investigation (code FI) the inspection has revealed an apparent deficiency which may result in a code CI or C2, and could not, due to the extent or limitations of the inspection, be fully identified. Such observations should be investigated without delay. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section 7).
- 10. For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The recommended date by which the next inspection is due is stated in Section 7 of the Report under Recommendations.
- 11. Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.
- 12. Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should. be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.
- 13. Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.
- 14. Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.